



L'anse Creuse High School North and Marie C. Graham Elementary School

23700 21 Mile Rd, Macomb, MI 48042 and 25555 Crocker Blvd, Harrison Twp, MI 48045

L'anse Creuse Public School Summer of 2025 Roofing Replacements Addendum

- Bids are now due by January 22nd, 2024 no later than 2:00 p.m. and are to be delivered to the Harry L. Wheeler Community Center & Administration Offices at 24076 Frederick V. Pankow Blvd, Clinton Township, MI 48036.
- All lightning protection at the high school is to be removed.
- New walkways are to match the existing walkways with TremTred.
- All dead curbs are to be removed.
- At Marie C. Graham Elementary School, the blue coping is to remain, but must be re-caulked using Tremseal Pro.
- Include unit pricing for new drains, clamping rings, and strainers.
- Do not use 3.5" ISO for flat insulation roofing areas. Use 1.5" and 2" ISO. Mechanically attach the first layer and set in asphalt all subsequent layers.
- For fully tapered areas use ¼" saddles, for flat insulation areas use ½" saddles.
- Horizontal roofing perimeters are to be 3 course with THERmastic 80 and 6" BURmesh.
- 24 gauge metal is to be shop fabricated.
- Per the specification, generic polyisocyanurate insulation and ¼" Tremboard AC is to be used.
- All prevailing wage requirements are required to be followed by bidding contractors.